



First Choice for Security Professionals

Thermal Network Bullet Camera & Turret Camera

Version: V5.5.42 build 210721

Release Note

(2021-8-10)



First Choice for Security Professionals

Index

| | | |
|-----|---|---|
| 1. | Basic Information | 3 |
| 2. | New Features | 4 |
| 2.1 | New Models | 4 |
| 3. | Optimized Features | 4 |
| 3.1 | VCA Optimization..... | 4 |
| 3.2 | Fix the issue that temperature unit centigrade degree showed garbled..... | 4 |
| 4. | Supported Product List | 4 |
| 5. | Third-party Integration | 5 |
| 6. | Client and Platform Compatibility..... | 6 |
| | Customer Impact and Recommended Action | 6 |



First Choice for Security Professionals

1. Basic Information

| | |
|-------------------------------------|-----------------------------------|
| Firmware Version | V5.5.42 build 210721 |
| SDK Version | V6.1.6.25 build20201222 |
| Play Lib | 7.3.9.55 Win32_Base_Build20210507 |
| iVMS-4200 | V3.5.1.4 build20210602 |
| Web Component/Plugin Version | V4.0.1.0 build 210707/3.0.7.42 |
| Behavior analysis algorithm version | V3.5.4build20210708 |

2. New Features

2.1 New Models

Added models: DS-2TD2367-50/PY, DS-2TD2367-75/PY, DS-2TD2367-100/PY, DS-2TD2667-15/PY, DS-2TD2667-25/PY, DS-2TD2667-35/PY, DS-2TD2637-10/PY, DS-2TD2637-15/PY, DS-2TD2637-25/PY, DS-2TD2637-35/PY, DS-2TD2637T-7/P.

3. Optimized Features

3.1 VCA Optimization

- Update animal model in the algorithm to reduce animal false alarms.
- Newly add birds training samples in the algorithm to reduce false alarm caused by crow.
- Newly add vehicles training samples in algorithm to reduce false alarm caused by stationary vehicles with local part high temperature.
- Newly add vehicles training samples in algorithm to improve the alarm rate triggered by car in the close range.
- Line crossing algorithm optimization to improve line crossing alarm rate.
- Algorithm optimization to improve alarm rate triggered by human and vehicle.
- Tracking strategy optimized, solved the drift problem of the target box.
- Size filter default parameter adjusted, reduced false alarm rate.

Note: Only applicable for 160 x120 resolution devices.

3.2 Fix the issue that temperature unit centigrade degree showed garbled.

4. Supported Product List

| | | | |
|-----------------|-----------------|-----------------|-----------------|
| DS-2TD1117-2/P | DS-2TD1217-2/P | DS-2TD2117-3/P | DS-2TD2617-3/P |
| DS-2TD1117-3/P | DS-2TD1217-3/P | DS-2TD2117-6/P | DS-2TD2617-6/P |
| DS-2TD1117-6/P | DS-2TD1217-6/P | DS-2TD2117-10/P | DS-2TD2617-10/P |
| DS-2TD1117-2/PA | DS-2TD1217-2/PA | DS-2TD2117-3/PA | DS-2TD2617-3/PA |



First Choice for Security Professionals

| | | | |
|------------------|-------------------|------------------|-------------------|
| DS-2TD1117-3/PA | DS-2TD1217-3/PA | DS-2TD2117-6/PA | DS-2TD2617-6/PA |
| DS-2TD1117-6/PA | DS-2TD1217-6/PA | DS-2TD2117-10/PA | DS-2TD2617-10/PA |
| DS-2TD1217T-2/PA | DS-2TD1217-2/PAH | DS-2TC1217-2/PA | DS-2TD2617T-3/PA |
| DS-2TD1217T-3/PA | DS-2TD1217-3/PAH | DS-2TC1217-3/PA | DS-2TD2617T-6/PA |
| DS-2TD1217T-6/PA | DS-2TD1217-6/PAH | DS-2TC1217-6/PA | DS-2TD2617T-10/PA |
| DS-2TD2117-3/PI | DS-2TD2117-3/PAI | DS-2TD2617-3/PI | DS-2TD2617-3/PAI |
| DS-2TD2117-6/PI | DS-2TD2117-6/PAI | DS-2TD2617-6/PI | DS-2TD2617-6/PAI |
| DS-2TD2117-10/PI | DS-2TD2117-10/PAI | DS-2TD2617-10/PI | DS-2TD2617-10/PAI |
| DS-2TD2137-4/P | DS-2TD2137-15/P | DS-2TD2637-10/P | DS-2TD2637-35/P |
| DS-2TD2137-7/P | DS-2TD2137-25/P | DS-2TD2637-15/P | DS-2TD2137T-4/P |
| DS-2TD2137-10/P | DS-2TD2137-35/P | DS-2TD2637-25/P | DS-2TD2137T-7/P |
| DS-2TD2367-50/P | DS-2TD2367-75/P | DS-2TD2367-100/P | |
| DS-2TD2637T-10/P | DS-2TD2637T-15/P | | |
| DS-2TD2137-4/PI | DS-2TD2137-15/PI | DS-2TD2637-10/PI | DS-2TD2637-35/PI |
| DS-2TD2137-7/PI | DS-2TD2137-25/PI | DS-2TD2637-15/PI | |
| DS-2TD2137-10/PI | DS-2TD2137-35/PI | DS-2TD2637-25/PI | |
| DS-2TD2137-4/PY | DS-2TD2137-7PY | DS-2TD2137-10/PY | DS-2TD2137-15/PY |
| DS-2TD2137-25/PY | DS-2TD2137-35/PY | | |
| DS-2TD2667-15/PY | DS-2TD2667-25/PY | DS-2TD2667-35/PY | |
| DS-2TD2167-7/P | DS-2TD2167-15/P | DS-2TD2167-25/P | DS-2TD2167-35/P |
| DS-2TD2667-15/P | DS-2TD2667-25/P | DS-2TD2667-35/P | DS-2TD2167T-7/P |
| DS-2TD2667T-15/P | DS-2TD2367-50/P | DS-2TD2367-75/P | DS-2TD2367-100/P |
| DS-2TD2167-7/PI | DS-2TD2167-15/PI | DS-2TD2167-25/PI | DS-2TD2167-35/PI |
| DS-2TD2667-15/PI | DS-2TD2667-25/PI | DS-2TD2667-35/PI | |

5. Third-party Integration



First Choice for Security Professionals

| Thermal cameral Version | | V5.5.42 build 210721 | | | | |
|-------------------------------------|---|-------------------------|------------|-------------------------|------------------|--|
| Test equipment | Milestone | Mirasys | Seetec | ONSSI | Axonsoft | |
| Version | Milestone XProtect series with Corporate 2017 R2 | VMS Enterprise, VMS Pro | Cayuga R10 | Ocularis 5.4(5.4.0.128) | Intellect 4.10.1 | |
| Live view(display VCA info) | √ | ✗ | ✗ | ✗ | ✓ | |
| Live view(display Fire point info) | ✗ | ✗ | ✗ | ✗ | ✗ | |
| Live view(display Temperature info) | ✗ | ✓ | ✗ | ✗ | ✗ | |
| Receive VCA Alarm info | √ | ✓ | ✓ | ✓ | ✓ | |
| Receive Dynamic Fire Detection info | √ | ✓ | ✗ | ✗ | ✗ | |
| Receive Temperature info | √ | ✓ | ✗ | ✗ | ✗ | |
| Tips | 1. The integration with milestone of fire detection and temperature measurement will be finished in Q3. 2. All thermal cameras support Onvif. 3. We have integrated with Mirasys to provide professional solution such as temperature analysis and historical analysis. 4. We integrated with milestone to show the VCA info by metadata, and the integration of different version of Milestone is as below. | | | | | |

6. Client and Platform Compatibility

| Thermal cameral Version | | V5.5.42 build 210721 | | |
|---|----------------------------|-----------------------------------|-------------|-------|
| Test equipment | iVMS-4200 | I series NVR | IE explorer | |
| Version | v3.2.50.7 build20200616 | DS-96XX-I16 NVR V4.1.50 180227 | | IE10+ |
| Live view(display VCA info) | √ | √(Web,4200) | √ | |
| Live view(display Fire point info) | √ | √(Web,4200) | √ | |
| Live view(display Temperature info) | √ | √(Web,4200) | √ | |
| Remote setup VCA rules (Line Crossing,Intrusion,Region Entrance,Region Exiting) | √ | √(Web) | √ | |
| Setup Dynamic Fire Detection | √ | √(4200, only support linkage) | √ | |
| Setup Temperature Measurement | √ | √(4200, only support linkage) | √ | |
| Receive VCA Alarm info | √ | √(4200) | ✗ | |
| Receive Dynamic Fire Detection info | √ | √(4200) | ✗ | |
| Receive Temperature info | √ | √(4200) | ✗ | |
| Playback(display VCA info) | √ | √(Web,4200) | √ | |
| Playback(display Fire point info) | √ | √(Web,4200) | √ | |
| Playback(display Temperature info) | √ | √(Web,4200) | √ | |

Customer Impact and Recommended Action

This update refers to function/compatibility improvement and will take effect automatically after the Date of Change. We are very sorry for any inconvenience of use-habit changes caused by this action.
For any questions and request for this firmware, please contact our local technical support team.

Remarks:



First Choice for Security Professionals

-
- Hikvision reserves the right to change, alter or withdraw the above notification without prior notice.
 - Product design and specifications are subject to change without prior notice.
 - The Hikvision firmware may contain errors known as errata which may cause the product to deviate from published specifications. Current characterized errata are available on request.
 - Hikvision is not liable for any typing or printing errors.

Hikvision Digital Technology CO., Ltd.
No. 555 Qianmo Road, Binjiang District, Hangzhou 310051,
China
Tel: +86-571-8807-5998
FAX: +86-571-8993-5635
Email: overseabusiness@hikvision.com